



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT

Tele phone No : 0497 2704380
email : kwaqckabkannur@gmail.com

Report No - KWA/QA/R/13/48(a)/J/14/12


Date : 27.09.2021

Customer Name and Address		1. Date of receipt		: 23.09.2021			
Royal School Sayyid Nagar, Taliparamba (LICENCE PURPOSES)		2. Sampling done by		Sampling done by party			
		3. Sample Code		: 22/21 (56)			
		4. Source of Sample		: Open well			
		5. Sample quantity		: 100ml			
		6. Test performing dates		From:23/09/2021		To: 24/09/2021	
Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result		
1	Total Coliforms	CFU /100 ml	IS 15185:2016; ISO 9308 - 1: 2014	Nil	21		
2	E.Coli	CFU /100 ml	IS 15185:2016; ISO 9308 - 1: 2014	Nil	4		

Remarks: Coliforms and E.coli present.

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

Authorised By


Bacteriologist


* End Of Report*

KWA/QC/KNR/R/17

Issue No: 02 Issue Date : 01.06.2021

Rev Date:

Rev No: 001
01.06.2021
BACTERIOLOGIST
QUALITY CONTROL REGIONAL LAB
KERALA WATER AUTHORITY
KANNUR-12



Principal
Royal English School
Affiliated to CBSE, No. 930789
School Code: 75777
Syed Nagar, Taliparamba
Kannur Dist., Kerala - 670 141